



NATIONAL
ENVIRONMENTAL
TESTING, INC.

SEP - 9 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

08/28/1998

NET Job Number: 98.05754
Page 1 of 3

Enclosed are the Analytical Results for the following samples submitted to NET, Inc. Indianapolis Division for analysis:

Project Description: TWICE WEEKLY WASTEWATER

Sample Number	Sample Description	Date Taken	Date Received
216112	2X WEEKLY	08/19/1998	08/19/1998

National Environmental Testing, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed.

Reproduction of this analytical report is permitted only in its entirety.

Project Representative

MIL0004678



NATIONAL
ENVIRONMENTAL
TESTING, INC.

SEP - 9 1998

Indianapolis Division
6964 Hillside Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTURING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

08/28/1998

Job No.: 98.05754

Page 2 of 3

Date Received: 08/19/1998

Job Description: TWICE WEEKLY WASTEWATER

Sample Number / Sample I.D.			Sample Date/	Analyst &		Reporting
Parameters	Result	Flag	Units	Date Analyzed	Method	Limit
216112	2X WEEKLY		08/19/1998			
Iron, ICP	0.57		mg/L	psc / 08/25/1998	EPA 200.7	<0.10
Lead, ICP	<0.080		mg/L	psc / 08/25/1998	EPA 200.7	<0.080
Silver, ICP	<0.020		mg/L	psc / 08/25/1998	EPA 200.7	<0.020
Zinc, ICP	0.18		mg/L	psc / 08/25/1998	EPA 200.7	<0.020

MIL0004679



NATIONAL
ENVIRONMENTAL
TESTING, INC.

SEP - 9 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250
Tel: (317) 842-4261
Fax: (317) 842-4286

FIELD REPORT

JOB #: 98.05754
CLIENT: MILBANK MFG.
PROJECT: TWICE WEEKLY WASTEWATER
DATE: 8/19/98
SAMPLER(S): MEM

An ISCO model 3710 auto sampler was used in the composite mode of operation. The sampler was equipped with a plastic composite jug, tygon suction line, battery, ice, and strainer.

All reusable equipment is decontaminated withalconox, tap water, 5% nitric acid, and deionized water. New tygon suction tubing was used for the sampler. A stainless steel strainer was also used for the sampling event.

The sampler was set to take a sample every 30 minutes for 8 hours.

Monitoring start 07:30 on 8/18/98
Monitoring end 15:00 on 8/18/98

The composite sample was clear.

Notes: Samples were preserved, in the field, in the appropriate containers with any required preservative.

MIL0004680



COMPANY Milbank Manuf King INC.
ADDRESS 1400 E. Havens St. Kokomo, IN 46901-3188
PHONE _____ FAX _____
PROJECT NAME/LOCATION _____
PROJECT NUMBER _____
PROJECT MANAGER _____

REPORT TO: Mr. R. d Tyler

INVOICE TO: _____

P.O. NO. _____

NET QUOTE NO. 98.0060

SAMPLED BY
Michael E. Milliken
(PRINT NAME)

(PRINT NAME)

7. C. Miller
SIGN 3E

SIGNATURE

and Type of Containers

ANALYSES

To assist us in selecting the proper method

Is this work being conducted for regulatory compliance monitoring? Yes _____ No _____

Is this work being conducted for regulatory enforcement action? Yes ☐ No ☐

Which regulations apply: RCRA _____ NPDES Wastewater _____
UST _____ Drinking Water _____
Other _____ None _____

COMMENTS

[illegible]

CONDITION OF SAMPLE: BOTTLES INTACT? ~~YES~~ / NO
FIELD FILTERED? YES / NO

~~COC SEALS PRESENT AND INTACT? YES / NO~~
~~VOLATILES FREE OF HEADSPACE? YES / NO~~

TEMPERATURE UPON RECEIPT: _____
Bottles supplied by NET? YES / NO

SAMPLE REMAINDER DISPOSAL: RETURN SAMPLE REMAINDER TO CLIENT VIA _____
I REQUEST NET TO DISPOSE OF ALL SAMPLE REMAINDERS _____

DATE _____

RELINQUISHED BY:

DATE 11/11/11

TIME

RECEIVED BY:

RELINQUISHED BY:

DATE _____

TIME

RECEIVED FOR NET BY:

METHOD OF SHIPMENT

REMARKS: